

Proposal for 1KWp Roof-Top Solar PV Plant

Jayanna Kanchikere¹, K. Kalyankumar²

¹Research Scholar, Vinayaka Mission Sikkim University, East Sikkim, INDIA

²Former Vice-Chancellor, Vinayaka Mission Sikkim University, East Sikkim, INDIA

Abstract - Energy demand in Karnataka state is increasing, however the electric utilities failed to meet this load demand. Photovoltaic (PV) solar power plant is used for larger development of solar power generation. In a solar roof top system, the solar panels are installed on the roof of any residential, commercial, institution and industrial building. The solar roof top system may come up with storage facility using battery or grid connected. The roof top system with storage facility has a battery to store solar electricity and can be utilized during night when sunlight is not available. In this research paper, it is aimed at providing technical details of 1KWp with 1.5KVA off grid solar roof top power plant on turnkey solutions and Simulation analysis is carried out using PV Syst for Davangere city location and simulation results of energy output of PV module, energy supplied to the load and unused energy are presented

Key Words: Grid, Roof top system, solar photovoltaic panel, solar radiation, Energy.

1. INTRODUCTION

Solar energy is a clean, pollution free renewable source of energy. Karnataka state being located between 11° 40' and 18° 27' North latitude and the geographical location favors the harvesting and development of solar energy. Karnataka state is having 300 sunny days with good solar radiation of 5.4 to 6.2 KWh / square-meter /day. Davangere city comes under Karnataka state in India which is 250KM from the Bangalore, the capital city of Karnataka state. The yearly average solar radiation on horizontal surface of Davangere city is 5.24 KWh/m²/day at latitude of 14.4384 °N and longitude of 75.956082 °E [6].

Electric utilities are finding it difficult to meet rise in peak demand and as a result, most of cities and towns are facing severe electricity shortages. Most of commercial establishments use one or more diesel generator for back-up power. In order to utilize the existing roof space of buildings, the scheme proposes to promote rooftop solar PV systems on buildings to replace diesel generator sets.

2. OFF-GRID ROOF TOP SOLAR POWER PLANTS

Solar PV cells converts sunlight to generate electricity through a photovoltaic process. There are two types of

solar PV systems: standalone and grid connected. Standalone solar PV systems work with batteries [5].

In off Grid rooftop solar power plant, the DC power generated from solar photovoltaic (SPV) panel is converted to AC power using inverter and is fed to the load through single phase lines and at the same DC power is stored in Battery during day time and loads are served by Battery back in night hours. A schematic sketch of a typical off grid solar rooftop photovoltaic power plant is shown in Fig1 [7].




Fig1. A Schematic sketch of a typical 1KWp off Grid Solar Roof Top Photo Voltaic Power Plant

3. COMPONENTS OF SOLAR PV SYSTEM

A Grid-connected solar PV system consists of following main components [1]:

A. Solar photovoltaic (PV) modules

Solar PV modules are mounted on the roof of buildings and convert sunlight into direct current. To achieve a required voltage and current, a group of PV modules are wired into large array called PV array.

B. Solar PV array support structure

These are galvanized steel structures secure the solar PV modules on the roof of building. The mounting structures require roof to be penetrated and mounting solar panels correctly is part of maximizing power generation

C. Solar Off-grid inverter

Solar Off-grid inverter converts generated direct current into alternating current which is required for all electrical appliances through a charge controller. It also regulates battery charging if required

D. Balance of system

All other components considered for solar rooftop power plant are cables, junction boxes, fuses etc. The size of solar plant require depends on requirement of electrical load, number of KWh consumption

4. REAL TIME SYSTEM DESIGN

The main target is to design and install 1KWP solar rooftop solar power plant [4].

A. Key facts of solar rooftop power plant

Plant capacity in Wp : 1KWp Rooftop Solar power plant
 PV Technology/Module: Poly crystalline modules
 Power conditioning unit: 1.5KVA
 Power evacuation : 230V AC, Single phase, 50HZ

B. Number of PV panels for the system

Capacity of each module: 250WP
 Number of PV panels or modules required = 04

Module area = 7.5m²
 Nominal PV Power = 1KWp
 Maximum PV Power =1KWdc
 Fixed Tilted plane = Tilt :30°; Azimuth :0°
 The maximum power of this module is 1KWP; hence it requires 04 modules to design 1KWP PV system. The selected PV is manufactured by Alfa Solar Ltd.
 The PV module parameters and ratings are given in Table 1[2].

Table1. PV module parameters and ratings

Electrical Characteristics	
Rated Maximum power (Pmax)	250Wp
Maximum power voltage (Vmp)	30.84 V
Maximum power current (Imp)	8.15A
Open circuit voltage (Voc)	37.26V
Short circuit current (Isc)	8.907A
Module efficiency	15.37%
Operating temperature	- 40°C to +85°C

The PV module specifications and dimensions are given in Table 2[2].

Table 2. PV module specifications and dimension

Specifications and Dimensions of PV module	
Solar cells	Multi crystalline solar cells
Solar cell size	156 mmx156 mm(6 inx6 in)
Number of cells(pieces)	60 (6x10)
Module dimensions	1644 mm x994 mm x50 mm
Weight	18.8 kg
Front glass	3.2 mm tempered glass
Frame	Anodized aluminum alloy
Protection degree	IP 65
High efficiency	17.4%
Grid connection	OFF grid
No. of PV modules/panels	04

C. Solar off- Grid Inverter rating

For this system, solar off grid inverter designed is 1.5KVA. The inverter parameters are given in Table 3

Table 3. Inverter parameters [3]

Inverter specifications	
1-phase inverter chosen	1.5KVA off grid inverter
Maximum efficiency	90%
Maximum ac output power	1000W
Rated ac power	900W
Rated ac off grid voltage	12V

D. Battery Back up

The battery maker is Electrona has following ratings.
 Each Battery rating : 150 Ah
 Total Number of batteries: 04
 Total Capacity : 600Ah
 Battery Voltage : 15V

E. Daily House Hold Consumptions

The daily house consumptions are given in Fig.2




Fig.2 The daily house consumptions

Total daily house hold energy needed = 4065Wh/day
 Total monthly house hold energy needed =122 KWh/month

5. SIMULATION ANALYSIS RESULTS

For simulation purpose, the considered PV module capacity is 1KWP, 15V Si-Poly with array current of 56.1A from Alfa Solar. The Considered battery capacity is 600Ah, 12V with stored energy of 7.2KWh from Electrona. Due to non- availability of correct make, it is considered from other manufacturers with appropriate ratings. The global system configuration of the PV array is shown in Fig.3 [7]

The simulation input and the main results of standalone 1KWP project are shown in Fig.5 [7]




Fig.3 The global system configuration of the PV array

The mateo for Davangere, synthetic data is shown in Fig. 4[7]




Fig.4 Mateo for Davangere city.




Fig.5 The simulation input and the main results of standalone 1KWP project

The standalone simulation parameters of 1KWP project are shown in Fig.6 [7]

Stand Alone System: Simulation parameters	
Project :	Stand Alone Project at Davangere
Geographical site :	Davangere
Situation :	Latitude 14.5°N Longitude 75.9°E
Meteo data :	Davangere , synthetic hourly data
Simulation variant :	Simulation date 15/05/17 11h37
Collector Plane Orientation :	Tilt 30° Azimuth 0°
PV Array Characteristics :	Model alfasolar 250 P
Number of PV modules :	4 modules
Array global power :	1.00 kWp
Array operating characteristic (50°C) :	15 V 56.1 A
PV Array loss factors :	Heat Loss Factor: 29.0 W/m²K, NOCT: 45 °C, Wiring Circuit Loss: 24.3 mOhm, Voltage Drop: 0.7 V, Series Diode Loss: 4.4 % at STC, Module Mismatch Losses: 3.0 %, Incidence effect, ASHRAE parameterization: IAM - 1-30 (1/005 I - 1)
System Parameter :	System type Stand Alone system
Battery :	Model Dural SC, Manufacturer Electrona, Voltage 12 V, No. of units 4 in parallel, Nominal Capacity 600 Ah
Regulator :	Mode General Purpose Default, Technology Undefined, Battery Management Thresholds: Charging 13.7/13.1 V, Discharging 11.8/12.6 V
User's needs :	Daily household consumers average 4.1 kWh/Day

Fig.6 The standalone simulation parameters of 1KWP project

The standalone system details of user's needs of 1KWP project are shown in Fig.7 [7]




Fig.7 The standalone system details of user's needs of 1KWP project

The standalone system main results of 1KWP project are shown in Fig.8 [7]




Fig.8 The standalone system main results of 1KWP project

The standalone system loss diagram over the whole year of 1KWP project are shown in Fig.9 [7]




Fig.9 The standalone system loss diagram over the whole year of 1KWP project

The standalone system energy output of array of 1KWP project are shown in Table 4[7]

	Simulation variant					
	EArray	E Load	E User	SolFrac	T LOL	Pr LOL
	kWh	kWh	kWh		Hour	%
January	125.0	126.0	120.0	0.952	34	4.6
February	118.4	113.8	113.7	0.999	0	0.0
March	126.0	126.0	120.7	0.958	30	4.0
April	117.4	122.0	115.4	0.946	38	5.3
May	105.6	126.0	106.0	0.841	116	15.6
June	88.3	122.0	85.7	0.703	213	29.5
July	87.8	126.0	78.2	0.620	280	37.7
August	96.5	126.0	95.3	0.756	179	24.1
September	102.3	122.0	98.3	0.806	138	19.2
October	103.7	126.0	102.3	0.812	139	18.7
November	92.9	122.0	89.0	0.730	193	26.9
December	102.5	126.0	95.8	0.761	176	23.6
Year	1266.4	1483.7	1220.4	0.822	1538	17.6

Table 4. The standalone system energy output of array of 1KWP project

The Global irradiation and array energy output and unused energy/day are shown in Fig.10 [7]




Fig.10 The Global irradiation and array energy output and unused energy/day

The balances and main Simulation results of 1KWP Project are given in Table 5[7].

Simulation variant								
Balances and main results								
	GlobHor	GlobEff	E Avail	EUnused	E Miss	E User	E Load	SolFrac
	kWh/m²	kWh/m²	kWh	kWh	kWh	kWh	kWh	
January	158.0	190.4	133.4	8.39	6.00	120.0	126.0	0.952
February	173.0	194.3	145.8	27.41	0.14	113.7	113.8	0.999
March	208.0	204.1	154.7	28.66	5.30	120.7	126.0	0.958
April	203.0	176.1	121.4	3.99	6.60	115.4	122.0	0.946
May	199.0	157.6	106.5	0.93	20.02	106.0	126.0	0.841
June	172.0	132.3	88.5	0.12	36.27	85.7	122.0	0.703
July	167.0	130.8	87.8	0.06	47.86	78.2	126.0	0.620
August	170.0	143.6	96.5	0.00	30.70	95.3	126.0	0.756
September	166.0	154.2	105.4	3.16	23.62	98.3	122.0	0.806
October	150.0	153.5	103.7	0.00	23.72	102.3	126.0	0.812
November	126.0	138.2	92.9	0.01	32.96	89.0	122.0	0.730
December	129.0	155.9	110.6	8.12	30.17	95.8	126.0	0.761
Year	2021.0	1931.0	1347.3	80.87	263.36	1220.4	1483.7	0.822

Table 5 The balances and main Simulation results of 1KWP Project

6. CONCLUSIONS

The research paper aimed providing technical details of 1KWp with 1.5KVA off grid solar roof top power plant on turnkey solutions and Simulation analysis is carried out using PV Syst at Davangere city location. From the simulation results, the horizontal global irradiation is

5.097 Kwh/m².day in different months in a year and the available energy at inverter output is 4.447 Kwh /day and energy demand is 4.065 KWh/month. In Jan-March, the PV module output is more than the load demand so we get excess energy in these months and in remaining months PV module output is equal to or slightly more than the demand. The energy demand is 120.7KWh/month in March month while energy output of PV module is 154.7 KWh/month and excess energy is 28.6 KWh / month and energy loss is 5.30KWh/month. The simulation results of energy output of PV module are presented. These outputs of PV module vary with respect to irradiation. The future growth can be enhanced to larger scale PV modules

REFERENCES

- [1] Jayanna Kanchikere and K KalyanKumar, "Estimation of cost analysis for 5KW grid connected solar roof top power plant: A case study", International Journal of engineering science and computing, vol 6, Issue 4, PP. 4505-4507, Apr 2016.
- [2] Jayanna Kanchikere, kotresh K and K KalyanKumar, "A 5KW photovoltaic solar roof top power plant design : An analysis", International Journal of engineering science and computing, vol 6, Issue 4, PP. 4501-4504, Apr 2016
- [3] Vinay Janardhan shetty and Keerti Kulkarni, "Estimation of cost analysis for 500KW grid connected solar photovoltaic plan: A case study", International Journal of current engineering and technology, vol 4, PP. 1859-1861, No.3, June 2014.
- [4] Hemakshi Bhoje, Gaurang and Sharma, " An analysis of one MW photovoltaic solar power plantdesign", International Journal of Advanced research in Electrical, Electronics and Instrumentation Engineering, vol 3, Issue 1, PP 6969-6973, Jan 2014.
- [5] Radhey S M, Jeetendra Singh Rathore and Shivani J, "Grid connected roof top solar power generation: A review", International Journal of Engineering development and research, vol 3, Issue 1, PP.325-330, 2014.
- [6] <https://eosweb.larc.nasa.gov/sse>.
- [7] www.pvsyst.com